


SEE ACWD STANDARD
DETAILS FOR LOCATION
& INSTALLATION

FACE OF CURB



- NOTE**
1. HYDRANTS SHALL BE THE EAST BAY CALIFORNIA FIRE HYDRANT MANUFACTURED UNDER LICENSE WITH THE EAST BAY MUNICIPAL UTILITY DISTRICT AS MANUFACTURED BY CLOW OR APPROVED EQUAL.
 2. HYDRANT SHALL BE INSTALLED IN ACCORDANCE WITH CURRENT ACWD SPECIFICATIONS AND STANDARD DRAWINGS.
 3. HYDRANTS SHALL BE PAINTED KEL-GUARD ENAMEL SAFETY YELLOW NO. 1700-63 MANUFACTURED BY KELLY-MOORE PAINT CO. OR APPROVED EQUAL.
 4. BLUE RAISED REFLECTIVE PAVEMENT MARKERS SHALL BE INSTALLED INLINE WITH THE HYDRANT IN THE PAVEMENT ACCORDING TO LATEST MUTCD.

CITY OF FREMONT
STANDARD DETAILS

FIRE HYDRANT

DATE APPROVED BY CITY COUNCIL
04/11/06

RESOLUTION NO. 2006-31

Ham Hughes

CITY ENGINEER

<i>MM</i>	Multiple Changes	1/13
APPR	REVISED	DATE
REVISIONS		

FILE NO. SD-34-06.DWG	SCALE NONE	DRAWN DC	CHECKED AR	DATE 05/21/07	DWG NO. SD-34	1 of 1
--------------------------	---------------	-------------	---------------	------------------	------------------	--------